

# Zertifikat *Certificate*

**Zertifikat Nr. Certificate No.** R 50225959  
**Blatt Page** 0001

**Ihr Zeichen Client Reference** G. J. Q.  
**Unser Zeichen Our Reference** 01-MR- 15048536 002  
**Ausstellungsdatum Date of Issue** 25. 04. 2012 (day/mo/yr)


**Genehmigungsinhaber License Holder**

HIMEL TECHNOLOGY, S.L.  
calle Bac de Roda,  
No. 52, edificio A  
08019 BARCELONA  
Spain

**Fertigungs#tte Manufacturing Plant**

01-MR-15048536 001

**Prüfzeichen Test Mark**



**Geprüft nach Tested acc. to**

EN 61008-1:2004+A11+A12  
EN 61008-2-1:1994+A11

**Zertifiziertes Produkt(Ger#teidentifikation)  
Certified Product (Product Identification)**

**Lizenzentgelte - Einheit  
License Fee - Unit**

Fehlerstrom-Schutzschalter (RCCBs)

Type Designation : HDB6VR (HIMEL)  
Number of Poles : 2P 4P  
Rated Operational Voltage : 230-240V 400-415V  
Nature of Supply : AC 50Hz  
Rated Current (In) : 10/16/20/25/32  
/40/63A  
Rated Residual Operating Current : 30/100/300/500mA  
Behavior in Presence of d.c. components: Type A or Type AC  
Rated Making and Breaking Capacity : 500A or 10In  
Rated Residual Making and Breaking Capacity : 500A or 10In  
Rated Conditional Short-circuit Current: 6,0kA  
Rated Conditional Residual Short-circuit Current : 6,0kA  
Suitability for Isolation : Yes  
Range of Ambient Air Temperature : -25° C - 40° C  
The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA.



8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**Zertifizierungsstelle**

**T#V Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com  
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Dipl.-Ing. F. He