

Certificate



Intertek


for European Product Safety

Reference No. 1122412

Moulded Case Circuit-breaker

Type designation	HDM1-400L
Certificate holder	Delixi Electric Ltd. Delixi High-Tech. Industry Park, Liushi Town, Yueqing, Zhejiang 325604, CHINA
The product complies with the standard(s)	EN 60947-2:2006
Date of expiry	1 July 2012
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Bo Berglöf	Date	26 October 2011 Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.



Intertek
Appendix


Reference No. 1122412

Technical data

Type designation/	HDM1-400L
Trade mark /	
Rated Voltage (V) /	400V
Rated Current (A) /	200, 225, 250, 315, 350, 400A
Frequency (Hz) /	50Hz
IP-class /	20
Poles No. /	3P
Product information /	$I_{cu}= 50kA, I_{cs}= 30kA, U_i= 800V\sim, U_{imp}= 6kA$
Manufacturing site(s)	Delixi Electric Ltd. Delixi High-Tech. Industry Park, Liushi Town, Yueqing, Zhejiang 325604, CHINA

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed 
Bo Berglöf Date 26 October 2011

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.